

DATE: 6 APRIL 2011

FROM: WALLER, TODD & SADLER ARCHITECTS, INC.  
1909 CYPRESS AVENUE  
VIRGINIA BEACH, VA 23451

TO: ALL PROSPECTIVE BIDDERS

RE: **ADDENDUM NO. 1**  
TO THE BIDDING DOCUMENTS FOR:  
**SUFFOLK POLICE RESPONSE FACILITY**  
**AND MISC. ALTERATIONS**  
SUFFOLK, VIRGINIA

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 12 March 2012 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

### **GENERAL**

Attached is the Pre-Bid Conference Attendees' List for your information.

### **PERTAINING TO THE SPECIFICATIONS**

#### 01410 SPECIAL INSPECTION SERVICES

**DELETE** the header of this section:

"ANIMAL CONTROL SHELTER WTS PROJECT 0706-D" and replace with the following:

"SUFFOLK POLICE RESPONSE FACILITY AND MISC. ALTERATIONS WTS PROJECT 1036-C"

#### 02821 CHAIN-LINK FENCES AND GATES

Paragraph 2.1.A., Subparagraph 2, Bullet a., **DELETE** "1-1/4-inches" and **REPLACE** with "2 inches".

Paragraph 2.1.A., Subparagraph 3, Bullet a., **DELETE** "1-1/4-inches" and **REPLACE** with "2 inches".

#### 02930 EXTERIOR PLANTS

Paragraph 1.3, **DELETE** this paragraph in its entirety.

Paragraph 1.4.A., **DELETE** Subparagraph 1. in its entirety.

#### 13125 METAL BUILDING SYSTEMS (PEB)

Paragraph 2.5.A., Subparagraph 1., **DELETE** "0.028-inch (0.71-mm)" and **REPLACE** with "24 gauge .0239-inch".

Paragraph 2.5.A., Subparagraph 5., **DELETE** "2-inches (51-mm)" and **REPLACE** with "1.5-inches (38.1-mm) to 2-inches (0.51mm)".

### **PERTAINING TO THE DRAWINGS**

SHEET C-502:

In Chain Link Fence Detail, **REVISE** the following: "1-1/4" CHAIN LINK FABRIC WITH SLATS" to "2" CHAIN LINK FABRIC WITH SLATS".

SHEET L-100:

- Show 5 Hollies on both base and bid option. See attached Sketch SKC-01

SHEET L-200:

- Revise schedule for appropriate amount of Hollies. See attached Sketch SKC-02.