

PHASE IIIA EXPANSION

ADDENDUM NO. 1
TO THE CONTRACT DOCUMENTS
for the construction of the

Date: June 12, 2012
IFB#: 2012-00053

City of Suffolk G. Robert House, Jr. WTP Phase IIIA Expansion Project

To All Planholders and/or Prospective Bidders:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of the City of Suffolk G. Robert House, Jr. WTP Phase IIIA Expansion Project dated May 2012 as fully and completely as if the same were fully set forth therein:

PART 1, PROCUREMENT REQUIREMENTS

1. All technical questions and other project related inquiries shall be submitted by 5:00 p.m. on Friday June 15, 2012. Inquiries received after this date and time may not receive a response. Submit all questions to the Purchasing Agent, Linda Story, by e-mailing lstory@suffolkva.us (preferred method) or faxing to 757-514-7524.

PART 3, SPECIFICATIONS

1. Section 44 44 63.05, Polymer Makeup and Feed Systems, Liquid and Dry:
 - a. Article 2.02.A.1: DELETE "Siemens, Stranco Division; Polyblend DP-500" (product no longer available) and REPLACE with "EnPro Technologies; ProBatch Model H".
2. Section 43 22 23, Centrifuges:
 - a. A sample of the residuals as currently pumped from the WTP's existing Sedimentation Basins to the on-site Sludge Lagoons may be obtained upon request. Requests should be made to Jay Maggi at jay.maggi@ch2m.com. Vendors making requests shall be responsible for providing a sample collection kit and shipping containers, and shall pay all shipping costs.

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 in the Bid Form or by submitting the Addendum with the bid package. Bid Forms submitted without acknowledgment or without this Addendum will be considered in nonconformance.

CITY OF SUFFOLK


Linda S. Story, CPPB, Purchasing Agent

END OF ADDENDUM