



CITY OF SUFFOLK

Purchasing Division

P.O. Box 1858, Suffolk, VA 23439-1858; T (757) 514-7520; Fax (757) 514-7524

ADDENDUM NO. 2

FOR THE
CONSTRUCTION OF

G. ROBERT HOUSE, JR. WATER TREATMENT PLANT SEWER FORCE MAIN EXTENSION HORIZONTAL DIRECTIONAL DRILL

CITY OF SUFFOLK, VIRGINIA

IFB NUMBER 2013-00089-MC

MAY 9, 2013

This addendum is issued to clarify, add to, delete from, correct and/or change the Invitation for Bid (IFB) documents to the extent indicated and is hereby made a part of the said IFB documents on which the construction contract will be based. Acknowledge receipt of the addendum by inserting its number and date on the bid form. Failure to do so may subject the offer or offeror to disqualification. All questions should be addressed to Michael Coburn (Agent) in writing, via fax at 757-514-7523 or via e-mail at mcoburn@suffolkva.us.

THIS ADDENDUM CONSISTS OF THE FOLLOWING:

- A. Responses to Bidder Questions
- B. Changes to the Project Manual

Issued by:

City of Suffolk – Purchasing Division
441 Market Street
Suffolk, Virginia 23434

Michael Coburn, Agent
Senior Buyer

A. RESPONSES TO BIDDERS QUESTIONS

1. Section 2622 of the specifications appears to be a proprietary specification for Fusible PVC pipe only. Will you allow fusion of HDPE pipe of equal size and pressure rating for the directional drill portion of the project??

Response: No. HDPE pipe was determined to be unsuitable for this project. However, the successful bidder (CONTRACTOR) can submit an alternative design that uses steel pipe for consideration by the OWNER and ENGINEER.

B. CHANGES TO THE PROJECT MANUAL

1. Table of Contents, Section C, Appendix C
 - a. Addendum No. 1 incorrectly stated the number of pages for "Army Corps of Engineers Nationwide 12 Permit". DELETE "46" and REPLACE with "15".

END OF ADDENDUM NO. 2