



# CITY OF SUFFOLK

## Purchasing Division

P.O. Box 1858, Suffolk, VA 23439-1858; T (757) 514-7520; Fax (757) 514-7524

## ADDENDUM NO. 2

### INVITATION TO BID NO. 2013-00091-CN

#### VILLAGE OF HOLLAND WATER TRANSMISSION MAIN CITY OF SUFFOLK, VIRGINIA

**Dated: May 20, 2013**

Bidders on the above-named Project are hereby notified that the documents have been revised as indicated below. All bid submittals shall conform to this Addendum. Bidders are responsible for familiarizing themselves with the modifications and the effect they may have on the scope of work.

The following changes are incorporated into the Bid Documents. Refer to the original contract documents for the complete specifications and Terms and Conditions.

**The Bid Date will not change. Bids will be accepted until 3:00 pm Wednesday, May 22, 2013**

#### **REVISIONS TO CONTRACT SPECIFICATIONS**

1. Section 33 05 23-4, Paragraph 2.01:

**DELETE** Paragraph 2.01.B and **REPLACE** with the following revised paragraph,

- B. Casing pipe and joints shall be of leak-proof construction, designed for the earth and groundwater pressures present, plus HS-20 design vehicle highway loads.

2. Section 33 10 00-5, Paragraph 2.01.B:

**DELETE** Paragraph 2.02.B.1 and **REPLACE** with the following revised paragraph,

1. Gate Valves: Mueller Company Model No. A-2360 or M&H valve Model No. 4067

**DELETE** Paragraph 2.03.A.2 in its entirety.

3. Section 33 10 00-7, Paragraph 2.03.A:

**DELETE** Paragraph 2.03.A.1 and **REPLACE** with the following revised paragraph,

1. 3 Inches through 12 inches: 250 psi working pressure. Gate valves larger than two-inches shall conform to AWWA C509 latest edition and shall be iron body, bronze mounted, mechanical joint ends, non-rising stem with an oil reservoir enclosed between two

"O" rings, one below and one above the thrust collar on the operating stem. Protective interior coating per AWWA C550.

**DELETE** Paragraph 2.03.A.2 in its entirety.

4. Section 33 10 00-8, Paragraph 2.03.C:

**DELETE** Paragraph 2.03.C.1 and **REPLACE** with the following revised paragraph,

1. Butterfly valves shall be ANSI/AWWA C504, Class 150B, cast iron, rubber seated, tight-closing type, with mechanical joint ends conforming to ANSI/AWWA C111/A21.11, latest edition, suitable for potable water use. Protective interior coating per AWWA C550.

**DELETE** Paragraph 2.03.C.3 in its entirety.

**DELETE** Paragraph 2.03.C.5 in its entirety.

END OF REVISIONS TO CONTRACT SPECIFICATIONS

**ATTACHMENTS:**

1. The attendees list from the Mandatory Pre-Bid conference is included as an attachment to this Addendum.

END OF ATTACHMENTS

All other parts of the Contract Documents remain unaltered except as noted by this Addendum and attachments. Bidders must acknowledge receipt of this Addendum on the revised Bid Form (BF-1). The Bid acceptance date and time remain the same.

**\*\* END OF ADDENDUM NO. 2 \*\***

Issued by: Cindy Norfleet, Senior Buyer  
City of Suffolk

Gary Heisler, P.E., Project Manager, AECOM



AECOM  
 440 Monticello Ave, Suite 1500  
 Norfolk, VA 23510  
 www.aecom.com

757.306.4000 tel  
 757.306.6784 fax

# Sign-in Sheet

Date/Time	May 7, 2013 (2:00 pm)
Meeting Purpose	Pre-Bid Meeting
Project Name	City of Suffolk - Village of Holland Water Transmission Main
AECOM Project No.	60247051

Name	Company/Agency	Phone No.	E-mail Address
Steve Showalter	Fertilizer	812-5803	steve.showalter@fertilizer.com
Frankie Bridgeman	T.A. Sheets Gen Con	627-3900	FRANKIE@TASHEETINC.COM
Brian Williams	MEB	487-5858	bwilliams@mebge.com
Norm Slack	Vico	487-3441	NSLACK@EAVIOLA.COM
Mike Dernebenny	BASIC Const Co	249-3789	mike-dernebenny@basicconstco.com
Andrew Dalk	MEB	487-5858	dalk@mebge.com
Jim Durrette	BRANSCOME INC	229-2504	durretted@branscome.com
BOB HYLAND	H D Supply	424-4604	bob.hyland@hdsupply.com
Rick Hall	WR Hall Inc	587-5074	wrhallinc@cox.net
Rodney Waldron	Water Works Inc	435-5136	rodney.waldron@waterworksinc.com
William Davis	Peters & White Const	487-1000	Extreme 1733 @ yahoo . com

This transmission is confidential and intended solely for the person or organization to whom it is addressed. It may contain privileged and confidential information. If you are not the intended recipient, you should not copy, distribute or take any action in reliance on it.



# Sign-in Sheet

Name	Company/Agency	Phone No.	E-mail Address
Scott Bland	Ferguson	757-630-5776	SCOTT.BLAND@Ferguson.com
Tom Marois	INTERVIEW LTD.	757-547-9711	INTERVIEWLTD@AOL.COM
Vince Hueft	Precision Pipe Inc	757-464-2611	VINCE@PRECISIONPIPEINC.COM
KEVIN LEWIS	LCOV/GSI	757-986-2273	LCOVSUFFOLK@AOL.COM
BRYAN MUENCH	GARNEY COMPANIES	417-459-1434	BMUENCH@GARNEY.COM
STEVE WRIGHT	ARTZ RAY CORP	757-539-8822	STEVE.WRIGHT@ARTRAYCORP.COM
Tommy Adkins	Tidewater Utility Co. Inc	757-679-9080	tadkins@tucincva.com
Courtney Fentress	Gaston Bros. Utilities	757-545-3206	cfentress@precononline.com
Jordan Hockaday	Henry S. Bransome LLC	757-221-7221	JHockaday@HSBLLC.com
Bruce C Keener	HENRY S BRANSOME LLC	757.221.7221	bkeener@hsbllc.com
RYAN BLAKE	SJ Louis Construction	320-253-9291	ryanb@sjlovis.com
Jim Schuelle	SJ Louis Construction	320-253-9291	JimS@SJLouis.com
CT Ludemann	Hudgins Contracting	757-873-0199	HCCorp@hudginscontracting.com
Janice Long	Nansemond River Contractors Corp.	757-465-1077	aviola@nr-cc.com
DANIEL GOOD	Bay Country Contractors	540-318-8633	dgood@baycc.net
FRANK TUCKER JR	KEVCO CONTRACTING	757-461-0700	KEVCOX2FET@AOL.COM
CHARLIE DOWLEN	KEVCO CONTRACTING	757-461-0700	charliedowlen@yahoo.com
CINDY NORFLEET	CITY OF SUFFOLK	514-7522	cnorfleet@suffolkva.us
Math Maxwell	Suffolk DPW	514 7009	mmaxwell@suffolkva.us
Jason Trimyar	Suffolk DPW Eng	514-7704	jtrimyar@suffolkva.us
Non Staple	Naream River Cont	487-3441	None
Gene Weaver	Suffolk D.P.U	514-7078	jweaver@suffolkva.us
Robert Lewis	SUFFOLK PW-TE	514-7603	relewis@suffolkva.us

