



ADDENDUM 1

INVITATION FOR BIDS

City of Suffolk

IFB # 2013-00094-MC

May 8, 2013

Purchasing Division

441 Market Street, Room 105

Suffolk, VA 23434-5237

Phone: (757) 514-7523/ Fax: (757) 514-7524

<http://www.suffolkva.us/purchasing>

WILROY ROAD WATER EXTENSION PROJECT (DPU NO. 532.120)

This constitutes Addendum 1 for the project and shall become part of the specifications. Bidders are asked to acknowledge receipt and understanding of this addendum as part of their submittal.

SCOPE OF WORK – Provide all plant, labor, superintendence, materials, tools, equipment, supplies, incidentals, and other ancillary items necessary, as identified in Section 01110 (Summary of Work) of these Contract Documents, in order to complete the construction of approximately 1135 linear feet of 12-inch, 2025 linear feet of 8-inch and 245 linear feet of 4-inch ductile iron water main and all associated appurtenances, and the abandonment of an existing 1-inch water line and associated potable water well to the limits shown on the drawings in accordance with all specifications, terms, conditions, and drawings herein.

Bid Due: 3:00 PM., May 20, 2013

**** SECTION "A" AND ONE ELECTRONIC CD COPY IS REQUESTED AS SUBMITTAL****

Acknowledged:

Company Name: _____

Address: _____

City / State / Zip: _____

Telephone: _____ FAX No.: _____

E-mail: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

Addendum 1

The following question was asked. Please note the response which shall become part of the specifications.

1. Is the stone bedding shown in the trench details on page D-04 required? If it is required, will it be paid for or is it incidental?

Response: The stone bedding in the detail is required and incidental to the pipe installation.