



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 1

City of Suffolk
IFB #2014-00061-JS
March 12, 2014

Purchasing Division
441 Market Street, Room 105
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/purchasing>

Route 17 Water Transmission Main

The Invitation for Bids for Route 17 Water Transmission Main March 7, 2014 has been amended as follows:

The following questions and answers are hereby incorporated in the IFB.

Q. What is the method of trenchless?

A. In accordance with Section 02400-Trenchless Crossing, the trenchless crossing will be performed using a boring method. As part of the submittal requirements, the contractor will submit their means and method for review.

Q. Are there any portions of the project that will need to be bored?

A. Yes – 1 crossing of Route 17.

Q. Are the crossings to be Jack & Bored or Directionally Bored?

A. In accordance with Section 02400-Trenchless Crossing, the trenchless crossing will be performed using a boring method. As part of the submittal requirements the contractor will submit their means and method for review.

Q. What is the diameter of the portions to be bored?

A. 42" casing with a 24" carrier pipe.

Q. How much is the estimate of the project?

A. The City of Suffolk prefers to allow bidders to determine their appropriate costs for the project.

The bidder will be required to acknowledge his/her receipt and acceptance of Addendum # 1 by submitting the addendum with their bid.

Contract Officer: _____

Jay Smigielski, Purchasing Agent,



If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us

Acknowledged by: _____ **Date:** _____