



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 2

City of Suffolk
IFB 2014-00108-JS
July 3, 2014

Purchasing Division
441 Market Street, Room 105
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/purchasing>

Signage for E911/Municipal Center

This addendum must be signed and included in your bid.

The Invitation for Bids for Signage for the new E911/Municipal Center has been amended as follows:

The following questions and answers are hereby incorporated in the IFB.

The 6" brushed stainless steel lettering:

Q: What is the letter thickness?

A: $\frac{1}{4}$ inch thick letters

Q: How are they mounted to the wall?

A: Mounted to the wall with either double sided adhesive tape (high bond strength) or silicone, at contractor's option.

Q: What is the soffit construction?

A: Soffit construction varies from painted gypsum wallboard (at the Information Desk) to wook paneling (at City Council Chamber entry) to aluminum (at revolving doors).

NOTE: The letters are actually called out as brushed aluminum, not stainless steel.

The stainless steel bar and rail:

Q: In the rail and bar on piece, if not how to they attach together?

A: The bar and rail can be fabricated as a single piece or fabricated out of two pieces at the option of the contractor. Attachment method for two piece option is determined by the sign fabricator.

Q: Can a side detailed view of these 2 pieces?

A: Attached to this addendum.

This addendum must be signed and returned with your proposal. Failure to do so will be justification for deeming the bid non-responsive.


Contract Officer:


Jay Smigielski, Purchasing Agent.

If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us

Acknowledged by: _____ Date: _____

SIGN TYPE



MOUNT: VIA 3M-VHB DOUBLE FACE TAPE AND SILICONE
 LOCATE: 60" ABOVE FLOOR LEVEL TO CENTER OF SIGN,
 TYPICALLY 3" OFF DOOR JAMB, DOOR HANDLE SIDE (OR
 CLOSEST ADJACENT WALL), SIGN MUST REMAIN OUT OF
 SWING OF DOUBLE DOORS / 3" FREE OF OBSTRUCTIONS

NOTES:

- 1 ADA 1" RAISED LETTERING INTERIOR GRADE PHOTOPOLYMER; TYPEFACE IS TREBUCHET - COLOR IS WHITE
- 2 CITY EMBLEM - PRINTED DIRECTLY TO SURFACE; COLOR IS WHITE
- 3 1/8" ACRYLIC; SURFACE PAINT RETURNS - COLOR IS BLACK
- 4 1/8" FROSTED TRANSLUCENT ACRYLIC - COLOR IS WHITE; MOUNT TO COMPONENT 7 WITH ADHESIVE
- 5 ADA 5/8" RAISED LETTERING INTERIOR GRADE PHOTOPOLYMER; TYPEFACE IS TREBUCHET - COLOR IS BLACK
- 6 ADA BRAILLE - INTEGRAL WITH BACKGROUND
- 7 3/16" x 1/4" STAINLESS STEEL BAR WITH 1/32" x 5/16" CONCEALED RAIL; HAND BRUSH WITH 240 GRIT PAPER - HORIZONTAL GRAIN; ATTACH TO COMPONENT 4 WITH ADHESIVE. SLIDE INTO NOTCH IN COMPONENT 8 AND 14.
- 8 1/8" ACRYLIC; SURFACE PAINT RETURNS - COLOR IS BENJAMIN MOORE - 1218 "COPPER KETTLE"; ROUTE NOTCH FOR COMPONENT 7 IN 2 LOCATIONS
- 9 1/8" TRANSLUCENT ACRYLIC - COLOR IS WHITE
- 10 1/8" ACRYLIC; SURFACE PAINT RETURNS - COLOR IS BENJAMIN MOORE - 1218 "COPPER KETTLE".
- 11 COMPUTER GENERATED GRAPHICS ON TRANSLUCENT INSERT; SLIDE IN FROM LEFT OR RIGHT SIDE; TEXT COLOR IS BLACK
- 12 1/32" SPACER WITH INSERT OPENING FOR NAME
- 13 1/8" Ø SET SCREW FLUSH WITH SURFACE
- 14 1/16" SPACER WITH NOTCH FOR COMPONENT 7