



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 2

City of Suffolk
IFB #15040-JS
November 25, 2014

Purchasing Division
442 West Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/purchasing>

The Invitation for Bids (IFB) for Water Meter Replacement Project has been amended as follows:

The following question and answer are hereby incorporated into this IFB:

- Q: The City's consultant stated that the pipe is to be welded. But after visiting several sites, no welded pipe was found. Welding concrete lined pipe will greatly increase the bid amount because of the steps required. All joints now threaded, unflanged or magaluged. Also found previously repaired pipe with spools and clamps that now would be a goodtime to change out to eliminate joints and future leaks.
- A: The use of welded flanges, threaded flanges or uniflances on cement lined ductile iron pipe as make-up pieces will be allowed.

For the combination meter replacements: The intent of the combination meter replacement is as shown in Detail MR-3. Should existing spool pieces and or clamps be encountered, they are to be removed to achieve the result shown in MR-3. Any such removal and subsequent make-up pipe shall be part of the contractor's price for that location.

Contract Officer:


Jay Smigielski, Purchasing Agent

Receipt of Addendum shall be acknowledged on the BID FORM. Failure to acknowledge addendum will be justification for deeming the proposal non-responsive.

If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us