



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 1

City of Suffolk
IFB #15062-JS
February 13, 2015

Purchasing Division
442 Market Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/purchasing>

The Invitation for Bids (IFB) for Shoulders Hill Water Transmission Main has been amended as follows:

SPECIFICATION CHANGES:

- I. **Replace the cover sheet** of the specifications with the attached signed and sealed cover sheet.
- II. **Replace the bid form** with the attached revised bid form.
- III. **Specification Section 33 50 00 Part 2, PRODUCTS** - Paragraph 2.14 has been revised to read:

"2.14 POLYETHYLENE ENCASEMENT

A. Approved manufacturers:

1. Van Leer/REPCOR
2. AA Thread Seal Tape, Inc.

B. Materials: ANSI/AWWA C105/A21.5, Class B, Seamless 4 mils thick high-density cross-laminated polyethylene. Flat tube form, minimum width based on nominal pipe diameter in accordance with recommendations by Ductile Iron Pipe Research Association."

IV. Appendix

1. Minutes from Pre-bid meeting of February 10, 2015.

2. Revised Bid Form

3. Geotechnical Report, replace the last two pages dated January 20, 2015 with the attached letter dated February 12, 2015 from GET.

4. Drawings

PLAN SHEET CHANGES:

- V. **Replace Cover:** updated index
- VI. **Replace Plan Sheet C-5:** updated profile
- VII. **Replace Plan Sheet C-8:** updated trench detail
- VIII. **Replace Plan Sheets CP-1, CP-2, and CP-3**
- IX. **Add CP-4**

Contract Officer:


Jay Smigielski, Purchasing Agent,

Receipt of Addendum shall be acknowledged on the BID FORM. Failure to acknowledge addendum will be justification for deeming the proposal non-responsive.

If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us