



## Addendum No. 1

City of Suffolk  
IFB #16019-CN  
May 25, 2016  
Purchasing Division  
442 West Washington Street, Room 1086  
Suffolk, VA 23434  
Phone: (757) 514-7522 Fax: (757) 514-7524  
<http://apps.suffolkva.us/bids/>

### Route 58 to Godwin Boulevard Ramp Improvements

Request for Bid (IFB) Number 16019-CN for Route 58 to Godwin Boulevard Ramp Improvements has been amended to include the following questions:

Question 1: Please clarify the gas line included on bid Item 74. What size and how long is the gas line?

**Response:** *The Contractor will need to coordinate with the gas company to determine the requirements to tap into their line and size/location or the cost for the gas company to connect to generator.*

Question 2: Please clarify bid Item 76 - Modify Existing Controller Cabinet. Are there any additional equipment or devices in the cabinet? (Will) the City / VDOT furnish new timings and reprogram controller, if required?

**Response:** *The bid item applies to the new cables that will connect from the existing controller to the proposed signal heads at the intersection and the connection of the existing controller cabinet to the new UPS cabinet and battery. The Contractor will be responsible for having timing plans developed and implemented. The Godwin Blvd. corridor has coordinated timing plans in place. The new timings for this signal will be required to work with the existing timing plans on the corridor.*

Question 3: Does the project specify an area for storage / laydown?

**Response:** *The Contractor will be responsible for securing storage/laydown area and any cost associated with same.*

Question 4: In reference to IFB 16019-CN, Rt. 58 to Godwin Blvd Ramp Improvements, the specifications state that this is a Locally Administered Project and that the contractor shall perform all Quality Control Testing. In our interpretation, the LAP Manual states that compaction testing and concrete testing is a Quality Assurance test and is the responsibility of the owner. Can you please confirm, and provide reference section from the LAP manual, as to who is to provide compaction testing and concrete testing for this project?

**Response: The cost for QC testing and inspections, in accordance with Chapter 13 of the LAP guide, is the responsibility of the contractor, and this cost shall be included in the bid prices for those items requiring testing and inspections per Chapter 13.**

Question 5: Are there DBE goals associated with the project?

**Response: There are no DBE goals for this project.**

Question 6: What are the work hours for the project?

**Response: Work hours are Monday through Friday, 8:00 a.m. to 4:00 p.m. Lane closures are only permitted between 9:00 a.m. and 3:00 p.m.**

Question 7: Can the contractor pay the City overtime for inspection staff?

**Response: The Contractor will not be allowed to pay for City inspector overtime.**

Question 8: Is the "traffic signal inspection fee" {Note 27, Sheet 7(1)} applicable for this project, or will it be waived as this is a project for the City?

**Response: The traffic signal inspection fee should be included with your bid pricing.**

Attendees of the Pre-Bid Conference held at 10:00 a.m. May 17<sup>th</sup> are as follows:


#### **Pre-bid Attendees**

Cindy Norfleet	City of Suffolk	757-514-7522	<a href="mailto:cnorfleet@suffolkva.us">cnorfleet@suffolkva.us</a>
Marie Salvas	Hudgins Contracting Corp	757-873-0199	<a href="mailto:hccorp@hudginscontracting.com">hccorp@hudginscontracting.com</a>
Sandon Rogers	City of Suffolk	757-514-7683	<a href="mailto:srogers@suffolkva.us">srogers@suffolkva.us</a>
Garth Donahue	JMT	757-552-1057	<a href="mailto:gdonahue@jmt.com">gdonahue@jmt.com</a>
Lee Rogers	Blair Brothers	757-538-1696	<a href="mailto:lrogers@blaribros.com">lrogers@blaribros.com</a>
Bobby Wynn	Paxton Contractors Corp	757-754-7140	<a href="mailto:bobby@paxtoncon.com">bobby@paxtoncon.com</a>
Kaitlyn Curtis	Curtis Contracting	804-843-4633	<a href="mailto:k.curtis@curtiscontracting.net">k.curtis@curtiscontracting.net</a>
Mike Cassell	Howard Brothers Contractor	504-512-3027	<a href="mailto:mike.cassel@hbcontractorinc.com">mike.cassel@hbcontractorinc.com</a>
Eric Miller	Trident Civil	757-452-4587	<a href="mailto:emiller@tridentcivil.com">emiller@tridentcivil.com</a>
Barbara Knight	Tidewater utility	757-935-5899	<a href="mailto:estimating@tucincva.com">estimating@tucincva.com</a>

The Bidder will be required to acknowledge his/her receipt and acceptance of Addendum Number 1 on the BID FORM.

The date for receipt of bids will remain at 3:00 p.m. June 1, 2016.

If you have any questions regarding this Addendum, please contact Cindy Norfleet, Senior Buyer, at (757) 514-7522.

A handwritten signature in black ink, reading "Cindy L. Norfleet", written over a horizontal line.

Cindy L. Norfleet, CPPB, Senior Buyer