



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 1

City of Suffolk
IFB #16012-AT
May 24, 2016

Purchasing Division
442 W. Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/purchasing>

Bridge Replacements Arthur Drive (Route 643)

The Invitation for Bid (IFB) issued May 13, 2016, has been amended as follows:

There was no information provided that warranted a change in the contract documents as advertised. The following provided was for information only.

1. The relatively recently completed construction of two bottomless culverts on Robbie Road Bridge and Manning Bridge Road Bridge Replacements are similar to this Arthur Drive Bridge Replacements project which is replacing two bridges with bottomless culverts. All of the procurement information and bid tabulations are still available on the Suffolk purchasing website for the two previous bridges.
2. The plans note that alternate barrel designs for the bottomless culverts will not be accepted. As the barrel shapes will likely be of precast concrete, it is the CONTRACTOR'S responsibility to maintain the proposed hydraulic opening at a minimum and not increase footing loads in the Contract Documents.
3. It was noted that the City has already cleared the trees associated with the permit for both bridges. It was noted stumps still remain and it is CONTRACTOR'S responsibility to remove as necessary for construction, as indicated in the Contract Documents.
4. The Verizon line has already been relocated at the southerly Arthur Drive Bridge #8034, as indicated in contract documents.
5. The potential for hazardous material with existing bridge demolition; such as lead paint on the steel beams, has been addressed in the contract documents.

Contract Officer: _____

Amy Trahan, Buyer I

If you have any questions regarding this Addendum, please contact Amy Trahan, Buyer I at atrahan@suffolkva.us.