



CITY OF SUFFOLK

Purchasing Division

442 West Washington Street, Suffolk, VA 23439-1858
T (757) 514-7520; Fax (757) 514-7524

June 15, 2016

ADDENDUM #1

Pruden Boulevard Drainage Improvements

IFB No. 16046-CN

Pre-Bid Conference

A Mandatory Pre-Bid Meeting was held on 6/9/16 at 10:00 A.M. The Sign In Sheet from the meeting is attached. Only Contractors whose representative was present at the meeting and are included on the sign-in Sheet are eligible to bid. The following are clarifications to the Bid Documents:

- 1) Price for the 2" neoprene pad shown on the detail "12" water line offset" on plan sheet CL201 shall be incidental and not paid separately.
- 2) The adapter to go from 8" to 10" HDPE bypass shall be included in the price for bid item 32 and considered part of Demolition Notes No. 11 on sheet CD101.
- 3) HDPE pipe stabilization (restrained in place to prevent movement) shall be included in bid item 32 and considered part of Demolition notes No. 11 on sheet CD101. The contractor shall submit the method of restraint and calculations for the sewer force main to The City for review and approval prior to commencing work.
- 4) The pump and haul disposal location shall be at Pump Station 41, 1062 Hillpoint Road.
- 5) Night work is understood to be part of this project and shall be coordinated with the Suffolk project manager a minimum of 48 hours prior to scheduling.
- 6) VDOT MB -10A is called out on the traffic control plan allowing for extended lane closures. It is required that one lane of traffic in each direction to be maintained at all times. The remainder of the roadway width in accordance with the MOT plan sheets (MT101 to MT106) is available for the workzone area. In accordance with Traffic Maintenance and Control Note 4 on Sheet C-001 the Contractor Shall submit detailed Traffic Control Plans to The City for review and approval thirty (30) days prior to the construction activity. Any proposed deviations from these plans must also be reviewed and approved by The City.
- 7) Offsite staging and stockpile areas are not provided by The City of Suffolk and if utilized The Contractor shall provide a hold harmless agreement to the City of Suffolk.

If you have any questions regarding Addendum Number 1, please contact the Senior Buyer, Cindy Norfleet, at (757) 514-7522 or via e-mail at cnorfleet@suffolkva.us.

Receipt of Addendum No. 1 must be acknowledged on the BID FORM.

MANDATORY PRE-BID CONFERENCE

Pruden Blvd. Drainage Improvements

10:00 a.m. June 9, 2016

	NAME	COMPANY	PHONE NUMBER	FAX NUMBER	E-MAIL
1.	Grindy Norfleet	City of Suffolk	514-7522	514-7524	cnorfleet@suffolkva.us
2.	Wilhelmina Gunter	Kovcor	461-0700	461-9345	wgunter@kovcorva.com
3.	Kent Foster	T.A. Sheets	627-3000	627-3550	kent@tarsheetssinc.com
4.	Sharon Moore	Gaston Brothers Utilities, LLC	545-3200	545-1874	smoore@gbu-hr.com
5.	GARY Thompson	TUDEWATER UTILITIES	757-235-5899		Gthompson@TUCincVA.com
6.	Shane Harris	Shaw Construction	757-281-9540		sharris@SCC-VA.COM
7.	BRANDON SAWYER	QUALITY ENTERPRISES USA, INC	757-548-8000	757-548-2600	BSAWYER@QEUSA.COM
8.	Stewart Lassiter	Suffolk DP4	514-7019		slassiter@suffolkva.us
9.	Gene Weaver	" "	514-7078		jweaver@suffolkva.us
10.	G. Allan Muehl	City of Suffolk	514-7681		Gmuehl@suffolkva.us
11.	John Parkinson	Clark Nexsen	961-7700		jparkinson@clarknexsen.com
12.	Bobby Dean	ULTRA Services Inc	898-4905	898-4906	INFO@ULTRA SERVICES INC.BIZ
13.	Tom McEachern	J. Sawdors Construction	(804)843-4700	(804)843-4251	thomas@J.Sawdors.net

14.	MIKE Cassell	Howard Brothers	804 512-3027	804-966-9214	Mike.Cassell@hbcontractorinc.com
15.	SAMUEL Howard	Howard Brothers CONTRACTOR INC.	804-966-2762 804-512-5378	804-966-9214	SAMUEL.HOWARD@ HB.CONTRACTOR.INC.COM
16.					
17.					
18.					
19.					
20.					
21.					
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					