



CITY OF SUFFOLK

Purchasing Division

442 West Washington Street, Suffolk, VA 23439-1858
T (757) 514-7520; Fax (757) 514-7524

June 21, 2016

ADDENDUM #2

Pruden Boulevard Drainage Improvements

IFB No. 16046-CN

Bidder Questions

The following are responses to Bidder Questions:

QUESTION 1: Tidewater Utility Construction Inc: Once work zone is setup with MB-10A barriers witch are made of concrete and bolted down does equipment need to be moved out of work zone each day?

RESPONSE: In accordance with The Virginia Work Area Protection Manual Appendix A, equipment can be stored behind the barrier as long as it is located outside of the deflection zone of the barrier.

If you have any questions regarding Addendum Number 2, please contact the Senior Buyer, Cindy Norfleet, at (757) 514-7522 or via e-mail at cnorfleet@suffolkva.us.

Receipt of Addendum No. 2 should be acknowledged on the BID FORM.

Cindy L. Norfleet, CPPB, Senior Buyer