



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 1

City of Suffolk
IFB #19104-JS
June 17, 2019

Purchasing Division
442 W. Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/739/Purchasing-Division>

The Invitation for Bid (IFB) for IFB 19104-JS for Fire Station # 1 Renovation (Phase II) for the Department of Fire & Rescue has been amended. The following questions, answers and attachments are hereby made a part of the Contract Documents for IFB 19104-JS as fully and completely as if the same were fully set forth therein:

The following questions and answers are incorporated in the bid:

Q1: Note 16 on CS101 calls out a card reader, please advise if this is by owner or contractor.

A1: Owner.

Q2: The specs read telescoping gate at 3 areas. Spec sheet C-504 shows a cantilever gate. These gates are approx. 50% longer than the width of the opening. On page CS101 the gates at the entrance to the parking lot appear to be double gates and the two by the building don't have the travel space needed to operate, or will be a possible hazard near the parking area. Please verify.

A2: The response to the question is as follows:

CS101

The drop arms on the west side of the parking lot have been keynoted. The correct detail is shown on revised sheet C-504.

The gate lengths have been called out and are 150% of the opening widths.

Added keynotes 24 - 26.

Revised keynote 14.

CG101

Additional grades and curb cuts to allow for gate operation.

C-501

Revised details for Motorized Telescoping Gate and Motorized Barrier Arm.

Attachment (3 pages)

Contract Officer:



Jay Smigielski, Purchasing Agent

All other specifications, provisions, terms and conditions of the IFB are unchanged.

Bidder shall acknowledge receipt of this Addendum on the Bid Form.

If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us