



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 3

City of Suffolk
IFB #20002-KP
August 19, 2019

Purchasing Division
442 W. Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/739/Purchasing-Division>

The Invitation for Bid (IFB) 20002-KP for Water System Repair Services Annual Contract for the Department of Public Utilities has been amended. The following attachments are hereby made a part of the Contract Documents for IFB 20002-KP as fully and completely as if the same were fully set forth therein:

Q1. Bid Item 36-40: OS&Y valves typically are hand wheel and flanged and installed in vault, just quote flange packs and valve?

A1. This was addressed in Addendum No. 2.

Q2. Bid Item 49: Meter boxes, should they be all small or all large huge price difference?

A2. Meter boxes shall be as follows:

- For ¾" – 1" water meters: Capitol Foundry of VA, Inc., Model MBX-1 (12-inch overall height), with cutout for touch read system
- For 1 ½" – 2" water meters: Capitol Foundry of VA, Inc., Model MBX-5A, with cutout for touch reach system

Q3. Bid Item 53: Hydrant assembly, is branch tee to be included and if so what size? There is a big difference in 6x6 versus 12x6.

A3. Any fittings required to install the fire hydrant assembly as a part of this bid item shall be included. Specific branch tee size will be dependent upon the diameter of the water main being connected to.

Q4. Bid Item 55-59: Saddles vary in price from ¾ cc to 2 cc

A4. Service saddle outlet tap size will be dependent upon the diameter of the new water service line.

Q5. Bid Item 64: Blow off assembly, what size saddle to quote if saddle is needed. There is a big price between 4x2 and 12x2

A5. Tapping saddle size will be dependent upon the diameter of the water main being connected to.

Q6. Bid Item 66-68: Water line installed, should the price include saddle, corp, copper, setter, meter box? What size saddles? There is a big price between 4x3/4 and 12x3/4 on a 3/4 service line. Also on a service line, is the city supplying the meter?

A6. Bid Item Nos. 66 through 68 should include all items listed in Special Provisions, 3.13, including the installation of a new City-furnished water meter, and should be based on furnishing, installing, and connecting a new 3/4" water service line to an existing or new 8-inch water main. The cost difference for the use of a larger diameter water service line or a larger service saddle (pipe diameter or outlet tap size) will be paid for under Schedule B.

Please submit entire Section A.

Contract Officer:


Kelly Pittman, Buyer

All other specifications, provisions, terms and conditions of the IFB are unchanged.

Bidder shall acknowledge receipt of this Addendum on the Bid Form.

If you have any questions regarding this Addendum, please contact Kelly Pittman, Buyer at kpittman@suffolkva.us.