



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 4

City of Suffolk
IFB #20002-KP
August 19, 2019

Purchasing Division
442 W. Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/739/Purchasing-Division>

The Invitation for Bid (IFB) 20002-KP for Water System Repair Services Annual Contract for the Department of Public Utilities has been amended. The following attachments are hereby made a part of the Contract Documents for IFB 20002-KP as fully and completely as if the same were fully set forth therein:


Further clarification for question no.1 on Addendum No. 3;

Q1. Bid Item 36-40: OS&Y valves typically are hand wheel and flanged and installed in vault, just quote flange packs and valve?

A1. This was addressed in Addendum No. 2. *This bid item covers the installation of an OS&Y gate valve inside a valve vault. It does not cover the installation or replacement of a valve vault.*

Please submit entire Section A.

Contract Officer:



Kelly Pittman, Buyer

All other specifications, provisions, terms and conditions of the IFB are unchanged.

Bidder shall acknowledge receipt of this Addendum on the Bid Form.

If you have any questions regarding this Addendum, please contact Kelly Pittman, Buyer at kpittman@suffolkva.us.