



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 2

City of Suffolk
IFB #20034-JS
June 12, 2019

Purchasing Division
442 W. Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524
<http://www.suffolkva.us/739/Purchasing-Division>

The Invitation for Bid (IFB) for IFB 20034-JS for Seaboard Coastline Trail Phase 2 for the Department of Parks and Recreation been amended. The following questions, answers and attachments are hereby made a part of the Contract Documents for IFB 20034-JS as fully and completely as if the same were fully set forth therein:


Q1: My question is about the model of bollard needed – the specification is our general spec that lists every option available but does not tell which of the options is to be used on this project. We did provide bollards for a previous project on this trail – should we assume the bollards for this current project are to be the same type?

A1: Yes, the same bollards used for the previous (Phase IV) trail project may be used for this project.

Q2: Question #2. For the project mentioned above, the plans say we need to have an engineer draw the bicycle/pedestrian railing for the bridge. They seem to already be drawn and designed on sheet S5, if we build them to match the drawing do we still need an engineer to draw and design them? For the wooden bicycle safety railing and split rail fence do we assume cedar for all wood as mentioned on the split rail fence detail or pressure treated for all the wood railings?

A2: Signed and sealed shop drawings are required for the bridge railing in accordance with Bicycle/Pedestrian Railing Note # 2 on Sheet S5. Timber for the wooden bicycle safety railing and split rail fence shall be preservative treated Southern Pine conforming to VDOT Road and Bridge Specifications, Section 236. Wood treatment shall be in accordance with the notes on Sheet 2D. Lumber.

Contract Officer:


Jay Smigielski, Purchasing Agent

All other specifications, provisions, terms and conditions of the IFB are unchanged.

Bidder shall acknowledge receipt of this Addendum on the Bid Form.

If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us