



# CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

## ADDENDUM NO. 1

City of Suffolk  
IFB #21024-AG  
October 8, 2020

Purchasing Division  
442 W. Washington Street, Room 1086  
Suffolk, VA 23434-5237  
Phone: (757) 514-7520 / Fax: (757) 514-7524  
<http://www.suffolkva.us/purchasing>

### Suffolk Pump Station No. 24 Replacement

#### QUESTIONS:

**CONTRACTOR QUESTION:** The HVAC Legend on contract drawing ME1 specifies EF-1 as 500 CFM, while specification section 15806, 2.03, B, 6. Specifies 900 CFM. Please clarify the required fan velocity for EF-1.

**ENGINEER'S RESPONSE:** The fan specifications are indicated on Contract Drawing ME1.

#### SPECIFICATIONS:

Section 15806 – Electric Unit Heaters and Ventilating Fans

**REMOVE** Section 15806 in its entirety.

Section 13344 – CS-FVNR Input/Output Point List

**REPLACE** Page 5, Section 13344 with the attached Page 5, Section 13344. This specification includes the following modifications:

1. Provisions for valve vault Flood Alarm Float

Section 13347 – CS-FVNR Station Control System Description

**REPLACE** Page 8, Section 13347 with the attached Page 8, Section 13347. This specification includes the following modifications:

2. Provisions for valve vault Flood Alarm Float

**DRAWINGS:**

Sheet M1 – Pump Station Plans and Sections

**REPLACE** Sheet M1 Pump Station Plans and Sections with the attached Sheet M1.

This drawing includes the following modifications:

1. Valve vault “Flood Alarm Float” added in plan and section views.
2. Added Note 13: Contractor to provide Uline mobile shop desk (Model No. H-7699) or equal.

Sheet S2 – Floor Plan

**REPLACE** Sheet S2 Floor Plan with the attached Sheet S2. This drawing includes the following modifications:

1. Increased the space between the screen wall column and the pump station building.

Sheet S3 – Elevations

**REPLACE** Sheet S3 Elevations with the attached Sheet S3. This drawing includes the following modifications:

1. Increased the space between the screen wall column and the pump station building.

Sheets I-1CSF through I-12CSF

**REPLACE** Sheets I-1CSF through I-12CSF with the attached Sheets I-1CSF through I-12CSF. These drawings include the following modifications:

1. Provisions for valve vault Flood Alarm Float.
2. Updated Terminal Box Details.

**There is no change to the date of bid opening which will occur at 3:00 PM on October, 28, 2020 as indicated in the original IFB #21024-AG**

**Contract Officer:** \_\_\_\_\_ *Amy Gardner* \_\_\_\_\_  
Amy Gardner, CPPB, Senior Buyer

If you have any questions regarding this Addendum, please contact Amy Gardner, Senior Buyer at [agardner@suffolkva.us](mailto:agardner@suffolkva.us) .

**Acknowledged by:** \_\_\_\_\_ **Date:** \_\_\_\_\_