



# CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

## ADDENDUM NO. 3

City of Suffolk  
IFB #21024-AG  
October 19, 2020

Purchasing Division  
442 W. Washington Street, Room 1086  
Suffolk, VA 23434-5237  
Phone: (757) 514-7520 / Fax: (757) 514-7524  
<http://www.suffolkva.us/purchasing>

### Suffolk Pump Station No. 24 Replacement

#### QUESTIONS:

- 
1. **CONTRACTOR QUESTION:** Section 16130—2.02 Pull, Junction and Outlet Boxes: Part 2.02.A.2 requires boxes for outdoor and indoor wet locations to be 304 Stainless Steel and 2.02.E.2 calls for 316 Stainless Steel. Please clarify the type of materials required for this project.

**ENGINEER'S RESPONSE:** Steel boxes shall be type 316 steel.

- 
2. **CONTRACTOR QUESTION:** Drawing S-6 shows traditional roof framing while Note 23/S-1 provides specifications for pre-engineered wood trusses. Please clarify the type of roof framing required.

**ENGINEER'S RESPONSE:** Roof framing shall be as depicted on drawing S-6.

- 
3. **CONTRACTOR QUESTION:** Note 12/M1 specifies an anodized finish for the aluminum screen wall however the named manufacturer (Ametco) informed us that powder coating is the only finish available for the listed model.
- Please advise if powder coat finish is acceptable for the screen wall.
  - If anodized finish is required, can you provide the name/model for acceptable manufacturers that provide this finish?

**ENGINEER'S RESPONSE:** The screen wall shall be powder coated per Drawing S-7, Section 3, Note 1.

## **SPECIFICATIONS:**

**REMOVE** the following specification sections:

- Section 15010 - Basic Mechanical Requirements
- Section 16000 - Basic Electrical Requirements
- Section 16111 - Conduit
- Section 16123 - Building Wire and Cable
- Section 16130 - Boxes
- Section 16141 - Wiring Devices
- Section 16170 - Grounding and Bonding
- Section 16190 - Supporting Devices
- Section 16195 - Electrical-Identification
- Section 16280 - Surge Protection Devices
- Section 16440 - Disconnect Switches
- Section 16470 - Panelboards
- Section 16476 - Enclosed Circuit Breakers
- Section 16500 - Lighting
- Section 16670 - Lightning Protection Systems
- Section 16902 - Electrical Controls and Relays

**ADD** the following specification sections:

- Section 16010 – Electrical General Provisions
- Section 16210 – Raceway Fittings and Boxes
- Section 16220 – Conductors
- Section 16230 – Wiring Devices
- Section 16250 – Safety Switches
- Section 16255 – Enclosed Circuit Breakers
- Section 16310 – Panelboards
- Section 16410 – Lighting Fixtures
- Section 16670 – Lightning Protection for Structures

## **DRAWINGS:**

Sheet S-1:

**REMOVE** general Note 23, Sheet S-1.

**There is no change to the date of bid opening which will occur at 3:00 PM on October, 28, 2020 as indicated in the original IFB #21024-AG**

Contract Officer: \_\_\_\_\_ *Amy Gardner* \_\_\_\_\_  
Amy Gardner, CPPB, Senior Buyer

If you have any questions regarding this Addendum, please contact Amy Gardner, Senior Buyer at [agardner@suffolkva.us](mailto:agardner@suffolkva.us) .

Acknowledged by: \_\_\_\_\_ Date: \_\_\_\_\_