



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 2

City of Suffolk

IFB #21001-AG

November 12, 2020

Purchasing Division

442 W. Washington Street, Room 1086

Suffolk, VA 23434-5237

Phone: (757) 514-7520 / Fax: (757) 514-7524

<http://www.suffolkva.us/purchasing>

Replacement of Pump Station 022

The Invitation for Bid (IFB) for IFB 21001-AG for Replacement of Pump Station 022 for the Department of Public Utilities has been amended. The following questions and answers are hereby made a part of the Contract Documents for IFB 21001- AG as fully and completely as if the same were fully set forth therein. There is no change to the bid opening date/time.

The following questions and answers are incorporated in the bid:

Q1: In reference to 02620-2.02 Pipe and fittings: "All fittings shall conform to C110", does this apply to buried 6" Force main DIP fittings? If so can C153 compact be acceptable for Buried FM fittings?

A1: Compact fittings in accordance with AWWA C153 will also be permitted.

Q2: In reference to 02620-2.02.D. Corrosion Resistant Coating: "The Exterior of all ductile iron pipe and fittings shall be coated with coal tar epoxy in accordance with ANSI/AWWA C151/A21.51". Does this apply to interior FM Flange pipe and fittings and Underground FM Pipe and fittings? If so, will Bituminous Exterior coating be acceptable for underground and Primed Exterior for interior Pipe and fittings? (for contractor to field coat)

A2: The exterior of the ductile iron pipe and fittings shall be coated with bituminous asphaltic coating in accordance with ANSI/AWWA C151/A21.51. The interior ductile iron force main pipe and fittings shall be coated with coal tar epoxy in accordance with Section 09900.2.01.C.

The following changes are incorporated into the specifications.

1. **Section 02620.2.02.C**
DELETE “the applicable requirements ANSI/AWWA C110/A21.10”, and the following
REPLACE WITH “the applicable requirements ANSI/AWWA C110/A21.10 or ANSI AWWA C153.A21.53”

2. **Section 02620.2.02.D**
DELETE “coal tar epoxy”
REPLACE WITH “bituminous asphaltic coating”

Contract Officer: _____ *Amy Gardner* _____
Amy Gardner, CPPB, Senior Buyer

If you have any questions regarding this Addendum, please contact Amy Gardner, Senior Buyer at agardner@suffolkva.us .

Acknowledged by: _____ Date: _____