



CITY OF SUFFOLK

P.O. BOX 1858, SUFFOLK, VA, 23439-1858, T: (757) 514-7520; FAX (757) 514-7524

ADDENDUM NO. 2

IFB #21023-JS
December 3, 2020
Purchasing Division
442 W. Washington Street, Room 1086
Suffolk, VA 23434-5237
Phone: (757) 514-7520 / Fax: (757) 514-7524

<http://www.suffolkva.us/739/Purchasing-Division>


The Invitation for Bid (IFB) for IFB 21023-JS for the Bridge Road Intersection project for the Department of Public Works has been amended. The following information, questions and answers is hereby made a part of the Contract Documents for IFB 21023-JS as fully and completely as if the same were fully set forth therein:

Q1: Where can the specifications for the DDMS Sign Assembly (qty2) be found? The IFB says to refer to the VDOT spec but I don't see DDMS size, character height, # of characters per line, LED color (RGB or monochrome).

A1: DDMS digital display specifications are provided in the project Special Provision for Dedicated Dynamic Message Sign, Section III (b) Equipment Display Specifications. These can be found on pgs. 189-190 of the IFB. The number of characters for each sign panel are provided in the Plans Sign Details, sheets 2AE and 2AF of the plans. The minimum number of characters per sign array are below for reference:

- ALT3(20(1)): 2 characters wide x 1 character high, 3 total arrays
- ALT3(31(1)): 3 characters wide x 1 character high, 2 total arrays

Contract Officer:


Jay Smigielski, Purchasing Agent

All other specifications, provisions, terms and conditions of the IFB are unchanged.

Acknowledgement of this addendum is required in the bid.

If you have any questions regarding this Addendum, please contact Jay Smigielski, Purchasing Agent at jsmigielski@suffolkva.us